



**REQUEST FOR BIDS (20-08)  
Re-Roofing Project**

**Addendum No. 3  
Addendum Issue Date: September 22, 2020**

This addendum is being issued to provide additional bidding information.

1. Approved application method for 20 year/72mph warranty-

Project - Capital Region Authority Airport, Lansing, MI. Warranty 20-year, 72-mph warranty. Maximum building height of 50-feet.

60-mil Sure-Seal EPDM with 6-inch FAT adhered to 2-layers of 2.6 InsulBase (20-psi) and Tapered InsulBase over a Steel 22-gauge.

Base layer of insulation adhered at 6" o.c. ribbons with FlexFAST adhesive, applied to the top of every flute. Each additional layer adhered with 12" o.c. ribbons in field and 6" o.c. in a 12-foot perimeter.

The Tower roof insulation will need to be installed 6" o.c. using FlexFAST adhesive.

2. Roof sections with existing gyp board will need 4x4 5/8" DensDeck Prime reinstalled and adhered 6" o.c.
3. Mechanically attaching the new 1.5" insulation to roofs RR, SS and TT is acceptable as long as fasteners do not penetrate the ceiling of canopy roofs.
4. All items above shall be included in base bid.